








-  1/4" PNEUMATIC TUBING FURNISHED, INSTALLED AND TERMINATED BY ATC
-  2 CONDUCTOR CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC
-  TWISTED SHIELDED PAIR FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  3 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  4 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC
-  6 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  10 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC

ENVIROTRAK CONTROL PANELS REQUIRE 120 OR 24 VAC BY OTHERS.

AIRFLOW AND FIELD WIRING DIAGRAM
ISOLATION ROOM – AIRFLOW TRACKING CONTROL

SUBMITTAL COPY

LABORATORY CONTROL SYSTEMS INC
 91 Quinton Road
 Scott Township, PA 18447
 (570) 487-2490

No.	Revision

Architect: Engineer: Contractor: LCS
 Drawn by: Chk by: CAD file: WebHosp01 Date: 01/15/20

ISOLATION ROOM
 AIRFLOW TRACKING CONTROL
 JOB NUMBER SHEET NO. OF