








-  1/4" PNEUMATIC TUBING FURNISHED, INSTALLED AND TERMINATED BY ATC
-  2 CONDUCTOR CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC
-  TWISTED SHIELDED PAIR FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  3 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  4 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC
-  6 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED, AND TERMINATED BY ATC
-  10 CONDUCTOR SHIELDED CABLE FURNISHED, INSTALLED AND TERMINATED BY ATC

ENVIROTRAK CONTROL PANELS REQUIRE 120 OR 24 VAC BY OTHERS.

AIRFLOW AND FIELD WIRING DIAGRAM

ISOLATION ROOM WITH ANTE ROOM – AIRFLOW TRACKING CONTROL

SUBMITTAL COPY

No.	Revision	Date

Architect:
Engineer:
Contractor: LCS
Drawn by:
Chk by:
CAD file: WebHosp04 Date: 01/15/20

ISOLATION ROOM WITH ANTE ROOM
AIRFLOW TRACKING CONTROL