



SINGLE DUCT TERMINAL UNIT WITH INTEGRAL SOUND ATTENUATOR AND HOT WATER COIL LSWA



SIZE	D	W	H	1 ROW		2 ROW		4 ROW		S
				M	WGHT	M	WGHT	M	WGHT	
05	4 7/8	10	10	43 1/4	24 LBS	44 5/16	26 LBS	46 7/16	30 LBS	5 3/8
06	5 7/8	10	10	43 1/4	24 LBS	44 5/16	26 LBS	46 7/16	30 LBS	5 3/8
07	6 7/8	12	10	43 1/4	27 LBS	44 5/16	29 LBS	46 7/16	34 LBS	5 3/8
08	7 7/8	12	10	43 1/4	37 LBS	44 5/16	39 LBS	46 7/16	44 LBS	5 3/8
09	8 7/8	14	12 1/2	43 1/4	34 LBS	44 5/16	37 LBS	46 7/16	44 LBS	5 3/8
10	9 7/8	14	12 1/2	43 1/4	34 LBS	44 5/16	37 LBS	46 7/16	44 LBS	5 3/8
12	11 7/8	16	15	43 1/4	39 LBS	44 5/16	44 LBS	46 7/16	52 LBS	5 3/8
14	13 7/8	20	17 1/2	43 1/4	48 LBS	44 5/16	54 LBS	46 7/16	66 LBS	5 3/8
16	15 7/8	24	17 1/2	43 1/4	55 LBS	44 5/16	61 LBS	46 7/16	75 LBS	5 3/8
24	24x16	38	18	43 3/4	127 LBS	44 5/16	134 LBS	46 7/16	153 LBS	5 7/16

- NOTES:
- WEIGHT ARE AN ESTIMATION AND WILL VARY BASED ON SELECTED OPTIONS, INSULATION TYPE, ETC.
 - 36" CLEARANCE REQUIRED BY NEC FOR ELECTRICAL ENCLOSURES.

- STANDARD FEATURES:
- PERFORMANCE CERTIFIED UNDER ARI STANDARDS 880 AND 410.
 - HEAVY GAUGE ZINC COATED STEEL, MECHANICAL LOCKING SEAMS CONSTRUCTION.
 - INSULATION MEETS REQUIREMENTS OF NFPA AND UL.
 - STANDARD 1" THICK MATTE-FACED DUAL DENSITY GLASS FIBER INSULATION
 - 3/8" CLOSED CELL "HOSPITAL" GRADE INSULATION
 - METAL LINER DOUBLE WALL CONSTRUCTION
 - ROUND DAMPER WITH LEAK-RESISTANT PERIMETER SEAL.
 - SLIP AND DRIVE CLEAT CONNECTIONS ON RECTANGULAR DISCHARGE.
 - RIGHT OR LEFT HAND CONTROL LOCATION.
 - MULTI - POINT CENTER AVERAGING AIR FLOW SENSOR USING LOG - LINEAR METHOD ADOPTED BY ARI AND AMCA.
 - GAUGE TEES FOR AIR FLOW MEASUREMENT.
 - 1/2" O.D COPPER TUBES.
 - ALUMINUM CORRUGATED FINS, 10 PER INCH.
 - CONNECTIONS:
 - SINGLE CIRCUIT - 1/2" O.D MALE SOLDER.
 - MULTI CIRCUIT - 7/8" O.D MALE SOLDER.
 - ACTUATOR
 - SOLID ONE PIECE DAMPER SHAFT.



All Dimensions are in Inches



Laboratory Control Systems Incorporated
91 Quinton Road
Scott Township, PA 18447
Tel: 570.487.2490 Fax: 570.487.2494
www.labcontrols.com

Title:
SINGLE DUCT TERMINAL UNIT WITH SOUND
ATTENUATOR AND HOT WATER COIL

Model Number:
LSWA

Drawing Number:
LSWA-DS-REVB

Date: 02/05/2020
Rev. B