

## 24 x 16 AIR FLOW VALVE AFT-P-24



## **GENERAL SPECIFICATIONS:**

- \* INLET/ DISCHARGE FRAMES ARE 20 GAUGE 316 STAINLESS STEEL
- \* DAMPER SECTION IS 18 GAUGE 316 STAINLESS STEEL HAT SHAPED CHANNEL FOR ADDED RIGIDITY
- \* LINKAGE IS EXTERNAL CHEVRON TYPE FORMED BRACKETS OF 1/8" STAINLESS STEEL
- \* BEARINGS ARE PRESS FIT STAINLESS STEEL FLANGED SLEEVE TYPE
- \* AXLES ARE 1/2" DIAMETER STAINLESS STEEL
- \* DRIVE SHAFT IS 1/2" EXTENDING 6" BEYOND FRAME
- \* DAMPER BLADES ARE 18 GAUGE 316 STAINLESS STEEL INTERLOCKING OPPOSED BLADE DEGIGN
- \* MEASURING STATION IS MULTIPLE POINT MULTIPLE TRAVERSE FOR IMPROVED MEASUREMENT ACCURACY



| DIMENS | DIMENSIONS (IN.) |  |  |  |
|--------|------------------|--|--|--|
| А      | 24               |  |  |  |
| В      | 16<br>24         |  |  |  |
| С      |                  |  |  |  |

| RANGE | FL0W@<br>0.01"H20 | FL0W@<br>0.10"H20 | FL0W@<br>1.00"H20 |
|-------|-------------------|-------------------|-------------------|
| I     | 870               | 2750              | 8700              |
| S     | 510               | 1612              | 5100              |
| S1    | 650               | 2055              | 6500              |
| 25    | 568               | 1798              | 5686              |

\*\*INSTALLATION NOTE: PLEASE ALLOW 60" STRAIGHT DUCT AT INLET



Laboratory Control Systems Incorporated 91 Quinton Road Scott Township, PA 18447 Tel: 570.487.2490 Fax: 570.487.2494 www.labcontrols.com Title:

24 x 16 AIR FLOW VALVE

Model Number:

AFT-P-24

Drawing Number: AFT-P-24-DS

Date: 02/05/2020

Rev. A