



MODEL	"D" (IN)	"A" (IN)	"B" (IN)	"C" (IN)	CFM RANGE (H)	CFM RANGE (L)
PVT-04	5 1/4	1	2	3	310	-
PVT-05	6 1/4	1 1/4	2 1/2	2 3/4	380	250
PVT-06	7 1/4	1 1/2	3	4 1/2	584	400
PVT-07	8 1/4	1 3/4	3 1/2	5 1/4	801	600
PVT-08	9 1/4	2	4	6	1088	800
PVT-09	10 1/4	2 1/4	4 1/2	6 3/4	1315	1050
PVT-10	11 1/4	2 1/2	5	7 1/2	1767	1300
PVT-12	13 1/4	3	6	9	2542	2000
PVT-14	15 1/4	3 1/2	7	10 1/2	3629	2800
PVT-16	17 1/4	4	8	12	4427	4000
PVT-18	19 1/4	4 1/2	9	13 1/2	----	----
PVT-20	21 1/4	5	10	15	----	----

ORDERING INFORMATION:

PART NUMBER = (MODEL) - (MATERIAL) - (RANGE)

MATERIAL (SS) - 302 STAINLESS STEEL
(AL) - ALUMINUM

RANGE (H) - HIGH CFM RANGE

(L) - LOW CFM RANGE

Ex: PART NUMBER PVT-12-SS-L FOR A 12" PLUG-IN DVT
IN STAINLESS STEEL W/ ORIFICE PLATE FOR LOW CFM RANGE

SUBMITTAL COPY

LABORATORY CONTROL SYSTEMS INC
91 Quinton Road
Scott Township, PA 18447
(670) 487-2490

NO.	REVISION	DATE
C	Changed Address	09/04/08
B	ADDED PVT-20	7/24/08
A	ADDED PVT-18	3/25/08

Architect: **MHQ**
Engineer: **MHQ**
Contractor: **MHQ**
Drawn by: **MHQ**
Chk by: **MHQ**
CAD file: **PVT-XX-YY-ZZ** Date: **12/17/02**

PLUG-IN DVT DETAIL

JOB NUMBER
SHEET NO. **1** OF